

**Bid 2088405242-B**

**Bid Due Date – August 17, 2017 at 10:00 am**

**960 sq. ft.**

**Gas, FHA**

**Cracked heat exchanger**

**non-operational**

**Unsafe to run**

**Boiler needs to be replaced**

**Add make-up air high/low snorkel**

**Pawtucket**

---

**City of Residence**