

Bid# 20111083-B

Bid Due Date – November 2, 2017 at 10:00 am

986 sq. ft.

Oil forced hot water w/ tankless

**Boiler is leaking between front and
middle section and evaporating up stack**

Bid out for replacement including indirect

Cumberland

City of Residence